 Austin Powder Argentina SA Petrochemical Division	N2O ABATEMENT PLANT AND PROCESS DATA			NACAG-ANNEX- 001
	Classification d	Review 1 Date: 04/08/24	Next Review Date: -	Page 1 of 4

Change control: New document

1	General plant information	
1.1	Plant type (Dual Pressure/Mono-High/Mono-Medium/Mono-Low)	Mono-High
1.2	Reactor supplier (Grande Paroisse , Uhde , Wetherley , other)	Girdler
1.3	Year of start-up	First in the 60s and new Commissioning in mid-2018
1.4	Number of reactors	1
1.5	Reactor pressure (bar, abs)	9
1.6	Reactor internal diameter in mm (basket)	800 (Hexagonal)
1.7	Gauze temperature (°C)	910
1.8	Production rate, design (100% Metric Tons HNO ₃ /day)	180
1.9	Production rate, real (100% Metric Tons HNO ₃ /day)	160
1.10	HNO ₃ concentration in the final product (%)	56
1.11	Normal duration of the productive campaign (months)	3
1.12	Operation time (days per year)	330
1.13a	Ammonia flow to reactor (kg/h)	2,000
1.13b	Ammonia flow to reactor (Nm ³ /h)	2,600
1.14	Primary air flow to ammonia reactor (Nm ³ /h)	24,000
1.15	Secondary air flow (Nm ³ /h)	1,550
1.16	Temperature of the gas mixture (air/NH ₃) to the reactor (°C)	240
1.17	Conversion efficiency of the plant at the beginning of the campaign (% or kgNH ₃ /teHNO ₃)	0.99
1.18	Plant conversion efficiency at the end of the campaign (% or kgNH ₃ /teHNO ₃)	0.88
2	Pt gauze per reactor	
2.1	Material (Pt% / Rh% / Pd%)	95/5
2.2	Diameter (mm)	800 (Hexagonal)
2.3	Number of gauze	42
2.4	Gauze supplier	Hereaus
3	Change of Pt gauze per reactor	
3.1	Average number of stops per campaign in the last three campaigns	14
3.2	Number of stops that were not planned	8
3.3	Date of next scheduled stoppage	Every 3 months for a mesh change and a general shutdown in July.



Austin Powder
Argentina SA
Petrochemical
Division

**N2O ABATEMENT
PLANT AND PROCESS DATA**

**NACAG-ANNEX-
001**

Classification
d

Review 1
Date: 04/08/24

Next Review
Date: -

Page 2 of 4

3.4	Planned changes to the composition of Pt gauze in the future?	NO
4	Reactor Basket / Pressure Drop Data	
4.1	Type of support system installed (basket with Raschig rings , others)	Mesh: Nickel / Chrome
4.2	Support system depth (mm)	120
4.3	Available depth for a secondary catalyst under gauze (mm)	260 Distance between the mesh and the top of the exchanger tubes
4.4	<u>Pressure drop tolerance in combustion reactor of:</u>	
	• Primary gauze (mbar)	-
	• Raschig ring bed (mbar)	-
	• Or full package (2 items above), (mbar)	-
5	NSCR and tail gas information	
5.1	NOx abatement unit installed (Yes / No)	Yeah
5.2	NOx abatement unit	Before expand
5.3	NOx reduction system type (SCR /NSCR)	NSCR
5.4	NSCR catalyst (precious metal, base metal, zeolite)	Pt-Rh-Pd Impregnating in ceramic base
5.5	NSCR Catalyst Supplier	ECS
5.6	Maximum temperature allowed in the NSCR reactor (°C)	732
5.7	NSCR catalyst age (years)	Lifespan: 3-4 years Last upload: April 2023
5.8	NOx regulation limit (ppm)	50
5.9	NOx content before the reactor (ppm)	5,500
5.10	NOx content after reactor (ppm)	< 50
5.11	Gas flow before NSCR (kg/h or Nm ³ / h)	25,000 kg/h
5.12	Gas flow after NSCR (kg/h or Nm ³ /h)	25,200 kg/h
5.13	Tail gas temperature at the outlet of the absorption tower (°C)	25
5.14	Tail gas temperature (°C) before NSCR	478 - 480
5.15	Tail gas temperature (°C) after NSCR	710 - 730
5.16	SCR O2 content (% vol.)	1.3 – 1.5%
5.17	Tail gas temperature (°C) before expander	590 - 610
5.18	Tail gas temperature (°C) before expander (max. Allowable)	620
5.19	Tail gas temperature (°C) after turbine	270 - 280
5.20	Tail gas pressure at the outlet of the absorption tower (bar a)	7.97



Austin Powder
Argentina SA
Petrochemical
Division

N2O ABATEMENT PLANT AND PROCESS DATA

**NACAG-ANNEX-
001**


Classification
d

Review 1
Date: 04/08/24

Next Review
Date: -

Page 3 of 4

5.21	Tail gas pressure at the absorption tower inlet (bar a)	7.97
5.22	Tail gas pressure (bar a) before turbine	6.4
5.23	Tail gas pressure (bar absolute) after turbine	~1
5.24	Tail gas flow (kg/h or Nm ³ / h)	25,200 kg/h
	<u>Reducing agents for NSCR:</u>	
5.25	<ul style="list-style-type: none"> • Ammonia Plant Purge Gas Flow (kg/h) • Natural Gas flow 	360 kg/h 200 kg/h
5.26	<ul style="list-style-type: none"> • Purge gas composition • Natural Gas Composition 	68% H ₂ – 3%Ar – 26%N ₂ - 3%NH ₃ 91% CH ₄ – 5.5% C ₂ H ₂ – 0.5% C ₃ H ₈ – 0.2% C ₄ H ₁₀ – 2.8% others
6	Chimney information	
6.2	Distance from chimney to control room (m)	100
6.3	Distance from sampling location (possible/existing) at chimney to ground level	30
6.4	Sampling platform required (Yes/No)	No
6.5	Access to the sampling platform (stairs)	Through stairs
6.6	O ₂ content in tail gases (% vol.)	1.3 – 1-5%
6.7	Maximum allowable additional pressure drop caused by the tertiary reduction system	0.2 kg/cm ² g
7	Steam generation with NSCR heat exchanger The pre- and post-NSCR boilers are considered.	
7.1	Steam flow generated (kg/h)	1,700
7.2	Generated steam temperature (°C)	200
7.3	Generated steam pressure (bar)	15 – 15.5
7.4	Use of generated steam	Turbine

 Austin Powder Argentina SA Petrochemical Division	N2O ABATEMENT PLANT AND PROCESS DATA		NACAG-ANNEX- 001
	Classification d	Review 1 Date: 04/08/24	Next Review Date: -

Juramento Nitric Acid Plant Gas Flow Diagram

