

 Austin Powder Argentina SA Petrochemical Division	N2O ABATEMENT PLANT AND PROCESS DATA			NACAG-ANNEX- 001
	Classification D	Review 2 Date: 27/02/25	Next Review Date: -	Page: 1 of 4


1	General plant information	
1.1	Plant type (Dual Pressure/Mono-High/Mono-Medium/Mono-Low)	Mono-High
1.2	Reactor supplier (Grande Paroisse , Uhde , Wetherley , other)	Girdler
1.3	Year of start-up	First commissioning in the 1960s (Canada) and new commissioning and EMP in mid-2018 (Argentina).
1.4	Number of reactors	1
1.5	Reactor pressure (bar, abs)	10
1.6a	Reactor internal diameter in mm (basket) (10-E-151)	756 mm (Circular)
1.6a	Reactor internal diameter in mm (basket) (10-R-201)	831,85 mm (Circular)
1.7	Gauze temperature (°C) (With new gauze)	910°C
1.8	Production rate, design (100% Metric Tons HNO ₃ /day)	180
1.9	Production rate, real (100% Metric Tons HNO ₃ /day)	170
1.10	HNO ₃ concentration in the final product (%)	56
1.11	Normal duration of the productive campaign (months)	3
1.12	Operation time (days per year)	330
1.13a	Ammonia flow to reactor (kg/h)	2.221
1.13b	Ammonia flow to reactor (Nm ³ /h)	2.892
1.14a	Primary air flow to ammonia reactor (kg /h)	33.168
1.14b	Primary air flow to ammonia reactor (Nm ³ /h)	25.711
1.15a	Secondary air flow (kg /h)	4.495
1.15b	Secondary air flow (Nm ³ /h)	3.333
1.16	Temperature of the gas mixture (air/NH ₃) to the reactor (°C)	240
1.17	Conversion efficiency of the plant at the beginning of the campaign (% or kgNH ₃ /teHNO ₃)	0.99
1.18	Plant conversion efficiency at the end of the campaign (%)	88-91
2	Pt gauze per reactor	
2.1	Material (Pt% / Rh%)	95/5
2.2	Diameter (mm)	831,85 mm (Circular)
2.3	Number of gauze	Cant: 13 X 3
2.4	Gauze supplier	Hereaus
3	Change of Pt gauze per reactor	
3.1	Average number of stops per campaign in the last three campaigns	2 (one scheduled for mesh change and one unplanned stoppage)

 Austin Powder Argentina SA Petrochemical Division	N2O ABATEMENT PLANT AND PROCESS DATA			NACAG-ANNEX- 001
	Classification D	Review 2 Date: 27/02/25	Next Review Date: -	Page: 2 of 4

3.2	Number of stops that were not planned	1
3.3	Date of next scheduled stoppage	Approx. Every 3 months for a mesh change and a general shutdown plant
3.4	Planned changes to the composition of Pt gauze in the future?	NO
4	Reactor Basket / Pressure Drop Data	
4.1	Type of support system installed (basket with Raschig rings , others)	Mesh: Nickel / Chrome
4.2	Support system depth (mm)	142,87mm
4.3	Available depth for a secondary catalyst under gauze (mm)	242,89mm Distance between the mesh and the top of the exchanger tubes
5	NSCR and tail gas information	
5.1	NOx abatement unit installed (Yes / No)	Yes
5.2	NOx abatement unit	Before expand (between boilers 10-BO-155/156)
5.3	NOx reduction system type (SCR /NSCR)	NSCR
5.4	NSCR catalyst (precious metal, base metal, zeolite)	Pt-Rh-Pd Impregnating in ceramic base
5.5	NSCR Catalyst Supplier	ECS
5.6	Maximum temperature allowed in the NSCR reactor (°C)	732
5.7	NSCR catalyst age (years)	Lifespan: 3-4 years Last upload: April 2023
5.8	NOx regulation limit (ppm)	50
5.9	NOx content before the reactor (ppm)	5,500
5.10	NOx content after reactor (ppm)	< 50
5.11a	Gas flow before NSCR (kg/h / h)	29.348
5.11b	Gas flow before NSCR (Nm ³ / h)	23.243
5.12a	Gas flow after NSCR (kg/h /h)	29.518
5.12b	Gas flow after NSCR (Nm ³ /h)	23.083
5.13	Tail gas temperature at the outlet of the absorption tower (°C)	28-34
5.14	Tail gas temperature (°C) before NSCR	470 - 485
5.15	Tail gas temperature (°C) after NSCR	710 - 730
5.16	NSCR O2 content (% vol.)	1.3 – 1.5% (up to 2.5% could be achieved but due to the requirements of the current abatement)

 Austin Powder Argentina SA Petrochemical Division	N2O ABATEMENT PLANT AND PROCESS DATA			NACAG-ANNEX- 001
	Classification D	Review 2 Date: 27/02/25	Next Review Date: -	Page: 3 of 4

		system it operates between 1.3-1.5%)
5.17	Tail gas temperature (°C) before expander	590 - 610
5.18	Tail gas temperature (°C) before expander (max. Allowable)	640
5.19	Tail gas temperature (°C) after turbine	240 - 270
5.20	Tail gas pressure at the outlet of the absorption tower (bar a)	7.7-8.2
5.21	Tail gas pressure at the absorption tower inlet (bar a)	8.7-9.2
5.22	Tail gas pressure (bar a) before turbine	7.5-8.0
5.23	Tail gas pressure (bar absolute) after turbine	~1
	<u>Reducing agents for NSCR:</u>	
5.24	<ul style="list-style-type: none"> • Ammonia Plant Purge Gas Flow (kg/h) • Natural Gas flow 	360 kg/h 200 kg/h
5.25	<ul style="list-style-type: none"> • Purge gas composition • Natural Gas Composition 	30 % CH ₄ ; 7 % H ₂ ; 26 % Ar; 37% N ₂ 91% CH ₄ – 5,5% C ₂ H ₆ – 0,5% C ₃ H ₈ – 0,2% C ₄ H ₁₀ – 2,8% otros
6	Chimney information	
6.2	Distance from chimney to control room (m)	100 aprox
6.3	Distance from sampling location (possible/existing) at chimney to ground level	30
6.4	Sampling platform required (Yes/No)	No
6.5	Access to the sampling platform (stairs)	Through stairs
6.6	O ₂ content in tail gases (% vol.)	0%
6.7	Maximum allowable additional pressure drop caused by the tertiary reduction system	0.2 kg/cm ² g
7	Steam generation with NSCR heat exchanger The pre- and post-NSCR boilers are considered.	
7.1	Steam flow generated (kg/h)	2650
7.2	Generated steam temperature (°C)	230
7.3	Generated steam pressure (bar)	15 – 15,5
7.4	Use of generated steam	Turbine

 Austin Powder Argentina SA Petrochemical Division	N2O ABATEMENT PLANT AND PROCESS DATA		NACAG-ANNEX- 001
	Classification D	Review 2 Date: 27/02/25	Next Review Date: -

Juramento Nitric Acid Plant Gas Flow Diagram

